

# **SEWER DEPARTMENT TOWN BOARD NOTES**

---

**07/ 20 / 2020**

## **Plant system.**

SBR #3 sludge pump will cost too much to repair quote was over \$7,000 new pump can be purchased for \$5,684.00.so I ordered new pump 8 to 12 weeks for delivery.

I have ordered a new 12 inch plug valve for SBR #3 Influent old valve is bad and locked up cost \$ 1,758.00. Will take 8 weeks for delivery. We will need a sub-contractor to help install it I am in process of trying to line one up.

## **Collection system.**

**N/A**

## **Other.**

**N/A**

**Notes by: John L. Hodge**